



CITY OF
Caldwell, Idaho

GARRET NANCOLAS
Mayor

208.455.3011
(f) 208.455.3003

City Hall
411 Blaine Street
Caldwell, Idaho 83605

Post Office Box
P.O. Box 1179
Caldwell, Idaho 83606

For a list of the City
Council members, visit:
Website
www.cityofcaldwell.com

IDEQ
Attn: Todd Crutcher
Engineering Manager
1445 N. Orchard St.
Boise, ID 83706
CC: James Craft
Date: 03/26/2019
RE: Ammonia

To Whom It May Concern,

It has come to our attention, on March 26th 2019 that the City of Caldwell Waste Water Treatment Plant produced an analysis result of 14.0 mg/L for ammonia on March 21st 2019. The cause was found to be the construction which caused and offset in biology. Due to lack of draining and rapid process changes the dead biology was being returned to the aeration basins causing insufficient processing of ammonia.

This letter is to comply with IPDES permit #ID0021504 requirements of written notification of said exceedance of ammonia. If you have any questions, please feel free to contact us.



Sincerely,
Sal Arreola, City of Caldwell



Prepared by
Roy Henson, Lab Tech, City of Caldwell

The Measure of the Valley