



X 45613	Floating solids, waste or visible foam-visual	Q - See Comments	0	--	Sample	=	1	9P - N=0;Y=1						01/30 - Monthly	VI - VISUAL	
					Permit Req.	<=	0 MO MAX	9P - N=0;Y=1					01/30 - Monthly	VI - VISUAL		
					Value NODI											
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	5.39	03 - MGD						99/99 - Continuous	RC - Recorder (auto)	
					Permit Req.		Req Mon MO AVG	Req Mon DAILY MX	03 - MGD					99/99 - Continuous	RC - Recorder (auto)	
					Value NODI											
81010	BOD, 5-day, percent removal	K - Percent Removal	0	--	Sample	=			95.9				23 - %	01/30 - Monthly	CA - CALCTD	
					Permit Req.					>=	85 MO AV MN			23 - %	01/30 - Monthly	CA - CALCTD
					Value NODI											
81011	Solids, suspended percent removal	K - Percent Removal	0	--	Sample	=			94.7				23 - %	01/30 - Monthly	CA - CALCTD	
					Permit Req.					>=	85 MO AV MN			23 - %	01/30 - Monthly	CA - CALCTD
					Value NODI											

**Submission Note**

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**

Code	Parameter Name	Monitoring Location	Field	Type	Description	Acknowledge
45613	Floating solids, waste or visible foam-visual	Q - See Comments	Quantity or Loading Sample Value 2	Soft	The provided sample value is outside the permit limit. (Error Code: 1)	Yes
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	Quantity or Loading Sample Value 1	Soft	The provided sample value is outside the permit limit. (Error Code: 1)	Yes
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	Quantity or Loading Sample Value 2	Soft	The provided sample value is outside the permit limit. (Error Code: 1)	Yes
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	Quality or Concentration Sample Value 2	Soft	The provided sample value is outside the permit limit. (Error Code: 1)	Yes
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	Quality or Concentration Sample Value 3	Soft	The provided sample value is outside the permit limit. (Error Code: 1)	Yes

**Comments**

**Attachments**

Name	Type	Size
2019_03_Lab_Statment_WWTP.pdf	pdf	152897
noncompliance_report_03-07-2019_ammonia.pdf	pdf	327477
March_26_2019_NH3_Exceedance.pdf	pdf	1377115
noncompliance_report_03-21-2019_ammonia.pdf	pdf	196610
2019_03_ALI_Lab_Statement.pdf	pdf	17754
2019_03_supporting_data.xlsx	xlsx	82567

**Report Last Saved By**

**CALDWELL, CITY OF**

User: SARREOLA@CITYOFCALDWELL.ORG  
 Name: Salvador Arreola  
 E-Mail: sarreola@cityofcaldwell.org  
 Date/Time: 2019-04-22 14:24 (Time Zone: -06:00)

**Report Last Signed By**

User: SARREOLA@CITYOFCALDWELL.ORG  
 Name: Salvador Arreola  
 E-Mail: sarreola@cityofcaldwell.org  
 Date/Time: 2019-04-22 14:24 (Time Zone: -06:00)