



45613	Floating solids, waste or visible foam-visual	Q - See Comments	0	--	Sample	=	0	9P - N=0;Y=1									01/30 - Monthly	VI - VISUAL
					Permit Req.	<=	0 MO MAX	9P - N=0;Y=1									01/30 - Monthly	VI - VISUAL
					Value NODI													
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	4.86	03 - MGD									99/99 - Continuous	RC - Recorder (auto)
					Permit Req.		Req Mon MO AVG	Req Mon DAILY MX	03 - MGD								99/99 - Continuous	RC - Recorder (auto)
					Value NODI													
81010	BOD, 5-day, percent removal	K - Percent Removal	0	--	Sample	=		95.98									01/30 - Monthly	CA - CALCTD
					Permit Req.	>=		85 MO AV MN									01/30 - Monthly	CA - CALCTD
					Value NODI													
81011	Solids, suspended percent removal	K - Percent Removal	0	--	Sample	=		93.94									01/30 - Monthly	CA - CALCTD
					Permit Req.	>=		85 MO AV MN									01/30 - Monthly	CA - CALCTD
					Value NODI													

**Submission Note**

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**

No errors.

**Comments**

**Attachments**

Name	Type	Size
2019_04_ALL_Lab_Statement.pdf	pdf	17404
2019_04_supporting_data.xlsx	xlsx	83758
2019_04_Lab_Statment_WWTP.pdf	pdf	370643

**Report Last Saved By**

CALDWELL, CITY OF

User: RKKEETON  
 Name: Kathryn Keeton  
 E-Mail: kkeeton@cityofcaldwell.org  
 Date/Time: 2019-05-16 16:21 (Time Zone: -06:00)

**Report Last Signed By**

User: SARREOLA@CITYOFCALDWELL.ORG  
 Name: Salvador Arreola  
 E-Mail: sarreola@cityofcaldwell.org  
 Date/Time: 2019-05-20 09:29 (Time Zone: -06:00)