



Parameter	Location	Units	Frequency	Sample	Permit Req.	Value NODI	Req Mon MO AVG	Req Mon DAILY MX	Req Mon WKLly AVG	19 - mg/L	01/30 - Monthly	24 - COMP24
00665 Phosphorus, total [as P]	G - Raw Sewage Influent	0	--	Sample								
				Permit Req.								
				Value NODI								
00671 Phosphate, ortho, dissolved [as P]	1 - Effluent Gross	0	--	Sample			= 3.5		= 3.5	19 - mg/L	01/30 - Monthly	24 - COMP24
				Permit Req.								
				Value NODI								
00681 Carbon, dissolved organic [as C]	P - See Comments	0	--	Sample			= 6.2		= 6.2	19 - mg/L	01/30 - Monthly	24 - COMP24
				Permit Req.								
				Value NODI								
00900 Hardness, total [as CaCO3]	P - See Comments	0	--	Sample			= 188		= 188	19 - mg/L	01/30 - Monthly	24 - COMP24
				Permit Req.								
				Value NODI								
01119 Copper, total recoverable	P - See Comments	1	--	Sample			= 5.5		= 6	28 - ug/L	01/30 - Monthly	24 - COMP24
				Permit Req.								
				Value NODI								
31648 E. coli, MTEC-MF	1 - Effluent Gross	0	--	Sample			= 6.6		= 41	13 - #/100mL	10/30 - Ten Per Month	GR - GRAB
				Permit Req.			<= 126 MO GEOMN		<= 406 INST MAX	13 - #/100mL	10/30 - Ten Per Month	GR - GRAB
				Value NODI								
45613 Floating solids, waste or visible foam-visual	Q - See Comments	0	--	Sample		= 0	9P - N=0;Y=1				01/30 - Monthly	VI - VISUAL
				Permit Req.		<= 0 MO MAX	9P - N=0;Y=1				01/30 - Monthly	VI - VISUAL
				Value NODI								
50050 Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample		= 8.4	= 8.9	03 - MGD			99/99 - Continuous	RC - Recorder (auto)
				Permit Req.		Req Mon MO AVG	Req Mon DAILY MX	03 - MGD			99/99 - Continuous	RC - Recorder (auto)
				Value NODI								
81010 BOD, 5-day, percent removal	K - Percent Removal	0	--	Sample			= 96.3			23 - %	01/30 - Monthly	CA - CALCTD
				Permit Req.			>= 85 MO AV MN			23 - %	01/30 - Monthly	CA - CALCTD
				Value NODI								
81011 Solids, suspended percent removal	K - Percent Removal	0	--	Sample			= 89.8			23 - %	01/30 - Monthly	CA - CALCTD
				Permit Req.			>= 85 MO AV MN			23 - %	01/30 - Monthly	CA - CALCTD
				Value NODI								

**Submission Note**

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**

No errors.

**Comments**

**Attachments**

Name	Type	Size
2019_07_ALI_Lab_Statement.pdf	pdf	16063
2019_07_supporting_data.xlsx	xlsx	84713
Noncompliance_report_08_15_2019_Phosphorus_Signed.pdf	pdf	335411
2019_07_Lab_Statment_WWTP.pdf	pdf	371847

**Report Last Saved By**

CALDWELL, CITY OF

User: RKKEETON

Name: Kathryn Keeton

E-Mail: kkeeton@cityofcaldwell.org

Date/Time: 2019-09-20 08:29 (Time Zone: -06:00)

**Report Last Signed By**

User: SARREOLA@CITYOFCALDWELL.ORG

Name: Salvador Arreola

E-Mail: sarreola@cityofcaldwell.org

Date/Time: 2019-09-20 10:51 (Time Zone: -06:00)