

DMR Copy of Record

Parameter		Monitoring Location	Season #	Param. NODI	Quantity or Loading			Quality or Concentration						# of Ex.	Frequency of Analysis	Sample Type		
Code	Name				Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units		
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample	= 229.67	= 320.33	26 - lb/d					3.59	= 5.01	19 - mg/L		02/07 - Twice Every Week	24 - COMP24
					Permit Req.	Req Mon MO AVG	Req Mon MX WK AV	26 - lb/d					Req Mon MO AVG	Req Mon MX WK AV	19 - mg/L		02/07 - Twice Every Week	24 - COMP24
					Value NODI													

Permit
 Permit #: **ID0021504** | Permittee: CALDWELL, CITY OF | Facility: CALDWELL, CITY OF - CALDWELL WWTP
 Major: Yes | Permittee Address: 621 E. CLEVELAND BLVD CALDWELL, ID 83605 | Facility Location: 208 JOHNSON LANE CALDWELL, ID 83605
 Permitted Feature: 001 External Outfall | Discharge: **001-C** Boise River

Report Dates & Status
 Monitoring Period: **From 10/01/19 to 10/31/19** | DMR Due Date: **11/20/19** | Status: **NetDMR Validated**

Considerations for Form Completion

Principal Executive Officer
 First Name: Brent | Title: Public Works Director | Telephone: 208-455-4678
 Last Name: Orton

No Data Indicator (NODI)
 Form NODI: --

Submission Note
 If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors
 No errors.

Comments

Attachments
 No attachments.

Report Last Saved By
CALDWELL, CITY OF
 User: KCHATTIN@CITYOFCALDWELL.ORG
 Name: Kaitlin Chattin
 E-Mail: kchattin@cityofcaldwell.org
 Date/Time: 2019-11-19 11:37 (Time Zone: -07:00)

Report Last Signed By
 User: SARREOLA@CITYOFCALDWELL.ORG
 Name: Salvador Arreola
 E-Mail: sarreola@cityofcaldwell.org
 Date/Time: 2019-11-20 09:56 (Time Zone: -07:00)