

DMR Copy of Record

Permit

Permit #:	ID0021504	Permittee:	CALDWELL, CITY OF	Facility:	CALDWELL, CITY OF - CALDWELL WWTP
Major:	Yes	Permittee Address:	621 E. CLEVELAND BLVD (MAILING ADDRESS) CALDWELL, ID 83605	Facility Location:	208 JOHNSON LANE CALDWELL, ID 83605
Permitted Feature:	001 External Outfall	Discharge:	001-H2 Boise River		

Report Dates & Status

Monitoring Period:	From 04/01/20 to 06/30/20	DMR Due Date:	07/20/20	Status:	NetDMR Validated
--------------------	----------------------------------	---------------	-----------------	---------	-------------------------

Considerations for Form Completion

See Permit Part 1.D, Table 1.

Principal Executive Officer

First Name:	Brent	Title:	Public Works Director	Telephone:	208-455-4734
Last Name:	Orton				

No Data Indicator (NODI)

Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3			
TT000	Toxicity, Chronic	1 - Effluent Gross	0	--	Sample						=	1.0	=	1.0	73 - toxic	02/RP - Twice Per Rpt Period	24 - COMP24
					Permit Req.						<=	1.61 MO AVG	<=	4.81 DAILY MX	73 - toxic		
					Value NODI												

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

No attachments.

Report Last Saved By

CALDWELL, CITY OF

User: BFAFORD-PIZER@CITYOFCALDWELL.ORG
 Name: Brenda Pizer
 E-Mail: bfaford-pizer@cityofcaldwell.org
 Date/Time: 2020-07-14 21:19 (Time Zone: -06:00)

Report Last Signed By

User: SARREOLA@CITYOFCALDWELL.ORG
 Name: Salvador Arreola
 E-Mail: sarreola@cityofcaldwell.org
 Date/Time: 2020-07-24 11:15 (Time Zone: -06:00)