

DMR Copy of Record

<b>Permit</b>					
Permit #:	<b>ID0021504</b>	Permittee:	CALDWELL, CITY OF	Facility:	CALDWELL, CITY OF - CALDWELL WWTP
Major:	Yes	Permittee Address:	621 E. CLEVELAND BLVD (MAILING ADDRESS) CALDWELL, ID 83605	Facility Location:	208 JOHNSON LANE CALDWELL, ID 83605
Permitted Feature:	001 External Outfall	Discharge:	<b>001-F</b> Boise River		

<b>Report Dates &amp; Status</b>					
Monitoring Period:	<b>From 11/01/19 to 10/31/20</b>	DMR Due Date:	<b>11/20/20</b>	Status:	<b>NetDMR Validated</b>

**Considerations for Form Completion**  
 Permit Table 1, Note 3 gives sampling procedures; report on Oct. DMR; P=Influent; Permit Part IB.8 gives sampling procedures; Q=Effluent; Permit Table I.B.8 gives sampling procedures

<b>Principal Executive Officer</b>					
First Name:		Title:		Telephone:	
Last Name:					

**No Data Indicator (NODI)**

Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3			
00718	Cyanide, weak acid, dissociable	P - See Comments	0	--	Sample						<	0.005	<	0.005	28 - ug/L	01/YR - Annual	CG - CMPGRB
					Permit Req.							Req Mon MO AVG		Req Mon INST MAX	28 - ug/L	01/YR - Annual	CG - CMPGRB
					Value NODI												
00718	Cyanide, weak acid, dissociable	Q - See Comments	0	--	Sample						=	0.005	=	0.005	28 - ug/L	01/YR - Annual	CG - CMPGRB
					Permit Req.							Req Mon MO AVG		Req Mon INST MAX	28 - ug/L	01/YR - Annual	CG - CMPGRB
					Value NODI												
00978	Arsenic, total recoverable	1 - Effluent Gross	0	--	Sample						=	9.73	=	10.0	28 - ug/L	01/YR - Annual	24 - COMP24
					Permit Req.							Req Mon MO AVG		Req Mon INST MAX	28 - ug/L	01/YR - Annual	24 - COMP24
					Value NODI												
00978	Arsenic, total recoverable	G - Raw Sewage Influent	0	--	Sample						=	11.3	=	12.7	28 - ug/L	01/YR - Annual	24 - COMP24
					Permit Req.							Req Mon MO AVG		Req Mon INST MAX	28 - ug/L	01/YR - Annual	24 - COMP24
					Value NODI												
00981	Selenium, total recoverable	1 - Effluent Gross	0	--	Sample						=	1.0	=	1.0	28 - ug/L	01/YR - Annual	24 - COMP24
					Permit Req.							Req Mon MO AVG		Req Mon INST MAX	28 - ug/L	01/YR - Annual	24 - COMP24
					Value NODI												
00981	Selenium, total recoverable	G - Raw Sewage Influent	0	--	Sample						=	1.0	=	1.0	28 - ug/L	01/YR - Annual	24 - COMP24
					Permit Req.							Req Mon MO AVG		Req Mon INST MAX	28 - ug/L	01/YR - Annual	24 - COMP24
					Value NODI												
01074	Nickel, total recoverable	1 - Effluent Gross	0	--	Sample						=	3.03	=	1.6	28 - ug/L	01/YR - Annual	24 - COMP24
					Permit Req.							Req Mon MO AV MN		Req Mon INST MAX	28 - ug/L	01/YR - Annual	24 - COMP24
					Value NODI												
01074	Nickel, total recoverable	G - Raw Sewage Influent	0	--	Sample						=	3.57	=	5.0	28 - ug/L	01/YR - Annual	24 - COMP24
					Permit Req.							Req Mon MO AVG		Req Mon INST MAX	28 - ug/L	01/YR - Annual	24 - COMP24
					Value NODI												
01079	Silver total recoverable	1 - Effluent Gross	0	--	Sample						=	0.2	=	0.2	28 - ug/L	01/YR - Annual	24 - COMP24
					Permit Req.							Req Mon MO AVG		Req Mon INST MAX	28 - ug/L	01/YR - Annual	24 - COMP24
					Value NODI												
01079	Silver total recoverable	G - Raw Sewage Influent	0	--	Sample						=	0.2	=	0.2	28 - ug/L	01/YR - Annual	24 - COMP24
					Permit Req.							Req Mon MO AVG		Req Mon INST MAX	28 - ug/L	01/YR - Annual	24 - COMP24
					Value NODI												
01094	Zinc, total recoverable	1 - Effluent Gross	0	--	Sample						=	27.33	=	28.0	28 - ug/L	01/YR - Annual	24 - COMP24
					Permit Req.							Req Mon MO AVG		Req Mon INST MAX	28 - ug/L	01/YR - Annual	24 - COMP24
					Value NODI												
01094	Zinc, total recoverable	G - Raw Sewage Influent	0	--	Sample						=	117.67	=	175.0	28 - ug/L	01/YR - Annual	24 - COMP24
					Permit Req.							Req Mon MO AVG		Req Mon INST MAX	28 - ug/L	01/YR - Annual	24 - COMP24
					Value NODI												
01113	Cadmium, total recoverable	1 - Effluent Gross	0	--	Sample						=	0.1	=	0.1	28 - ug/L	01/YR - Annual	24 - COMP24
					Permit Req.							Req Mon MO AVG		Req Mon INST MAX	28 - ug/L	01/YR - Annual	24 - COMP24
					Value NODI												

					Value NODI													
01113	Cadmium, total recoverable	G - Raw Sewage Influent	0	--	Sample	=	0.233	=	0.3	28 - ug/L	01/YR - Annual	24 - COMP24						
					Permit Req.		Req Mon MO AVG		Req Mon INST MAX	28 - ug/L	01/YR - Annual	24 - COMP24						
					Value NODI													
01114	Lead, total recoverable	1 - Effluent Gross	0	--	Sample	=	0.1	=	0.1	28 - ug/L	01/YR - Annual	24 - COMP24						
					Permit Req.		Req Mon MO AVG		Req Mon INST MAX	28 - ug/L	01/YR - Annual	24 - COMP24						
					Value NODI													
01114	Lead, total recoverable	G - Raw Sewage Influent	0	--	Sample	=	1.67	=	2.2	28 - ug/L	01/YR - Annual	CG - CMPGRB						
					Permit Req.		Req Mon MO AVG		Req Mon INST MAX	28 - ug/L	01/YR - Annual	CG - CMPGRB						
					Value NODI													
01118	Chromium, total recoverable	1 - Effluent Gross	0	--	Sample	=	1.0	=	1.0	28 - ug/L	01/YR - Annual	24 - COMP24						
					Permit Req.		Req Mon MO AVG		Req Mon INST MAX	28 - ug/L	01/YR - Annual	24 - COMP24						
					Value NODI													
01118	Chromium, total recoverable	G - Raw Sewage Influent	0	--	Sample	=	5.67	=	7.0	28 - ug/L	01/YR - Annual	24 - COMP24						
					Permit Req.		Req Mon MO AVG		Req Mon INST MAX	28 - ug/L	01/YR - Annual	24 - COMP24						
					Value NODI													
01119	Copper, total recoverable	G - Raw Sewage Influent	0	--	Sample	=	174.25	=	563.0	28 - ug/L	01/YR - Annual	24 - COMP24						
					Permit Req.		Req Mon MO AVG		Req Mon INST MAX	28 - ug/L	01/YR - Annual	24 - COMP24						
					Value NODI													
01129	Molybdenum, total recoverable	1 - Effluent Gross	0	--	Sample	=	4.5	=	4.6	28 - ug/L	01/YR - Annual	24 - COMP24						
					Permit Req.		Req Mon MO AV MN		Req Mon INST MAX	28 - ug/L	01/YR - Annual	24 - COMP24						
					Value NODI													
01129	Molybdenum, total recoverable	G - Raw Sewage Influent	0	--	Sample	=	6.13	=	7.2	28 - ug/L	01/YR - Annual	24 - COMP24						
					Permit Req.		Req Mon MO AVG		Req Mon INST MAX	28 - ug/L	01/YR - Annual	24 - COMP24						
					Value NODI													
01220	Chromium, hexavalent dissolved [as Cr]	1 - Effluent Gross	0	--	Sample	<	0.005	<	0.005	28 - ug/L	01/YR - Annual	24 - COMP24						
					Permit Req.		Req Mon MO AVG		Req Mon INST MAX	28 - ug/L	01/YR - Annual	24 - COMP24						
					Value NODI													
01220	Chromium, hexavalent dissolved [as Cr]	G - Raw Sewage Influent	0	--	Sample	<	0.0207	<	0.052	28 - ug/L	01/YR - Annual	24 - COMP24						
					Permit Req.		Req Mon MO AVG		Req Mon INST MAX	28 - ug/L	01/YR - Annual	24 - COMP24						
					Value NODI													
71901	Mercury, total recoverable	G - Raw Sewage Influent	0	--	Sample	=	0.2	=	0.2	28 - ug/L	01/YR - Annual	24 - COMP24						
					Permit Req.		Req Mon MO AVG		Req Mon INST MAX	28 - ug/L	01/YR - Annual	24 - COMP24						
					Value NODI													

**Submission Note**

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**

No errors.

**Comments**

**Attachments**

No attachments.

**Report Last Saved By**

**CALDWELL, CITY OF**

User: BFAFORD-PIZER@CITYOFCALDWELL.ORG  
 Name: Brenda Pizer  
 E-Mail: bfaford-pizer@cityofcaldwell.org  
 Date/Time: 2020-11-20 07:34 (Time Zone: -07:00)

**Report Last Signed By**

User: BRENTORTON  
 Name: Brent Orton  
 E-Mail: borton@cityofcaldwell.org  
 Date/Time: 2020-11-20 08:00 (Time Zone: -07:00)