

DMR Copy of Record

Permit		Permit #: ID0021504		Permittee: CALDWELL, CITY OF		Facility: CALDWELL, CITY OF - CALDWELL WWTP	
Major: Yes		Permittee Address: 621 E. CLEVELAND BLVD (MAILING ADDRESS) CALDWELL, ID 83605		Facility Location: 208 JOHNSON LANE CALDWELL, ID 83605			
Permitted Feature: 001 External Outfall		Discharge: 001-A Boise River					

Report Dates & Status			
Monitoring Period: From 06/01/21 to 06/30/21	DMR Due Date: 07/20/21	Status: NetDMR Validated	

Considerations for Form Completion
P=Effluent, See Table 1, Note 10 for samples to be collected on the same day; Q=Effluent, full narrative description in Permit Part I.B.3.; R=Effluent, Table 1, note 7. Report Mo Inst Max, Max Daily Avg, 7 Day Running Avg of Daily Inst Max

Principal Executive Officer		Title:	Telephone:
First Name:			
Last Name:			

No Data Indicator (NODI)
Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3			
00010	Temperature, water deg. centigrade	R - See Comments	0	--	Sample	=	21.14	=	21.11	=	21.49	04 - deg C		99/99 - Continuous	RC - Recorder (auto)		
					Permit Req.		Req Mon MX DA AV		Req Mon MX 7D AV		Req Mon INST MAX	04 - deg C	99/99 - Continuous	RC - Recorder (auto)			
					Value NODI												
00094	Conductivity	P - See Comments	0	--	Sample	=	7.34	=	7.34	11 - umho/cm		01/30 - Monthly	24 - COMP24				
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	11 - umho/cm	01/30 - Monthly	24 - COMP24					
					Value NODI												
00310	BOD, 5-day, 20 deg. C	1 - Effluent Gross	0	--	Sample	=	158.8	=	160.7	26 - lb/d	=	2.1	=	2.13	19 - mg/L	01/07 - Weekly	24 - COMP24
					Permit Req.	<=	2127.0 MO AVG	<=	3190.0 WKLY AVG	26 - lb/d	<=	30.0 MO AVG	<=	45.0 WKLY AVG	19 - mg/L	01/07 - Weekly	24 - COMP24
					Value NODI												
00310	BOD, 5-day, 20 deg. C	G - Raw Sewage Influent	0	--	Sample						=	248.2		19 - mg/L	01/07 - Weekly	24 - COMP24	
					Permit Req.						Req Mon MO AVG		19 - mg/L	01/07 - Weekly	24 - COMP24		
					Value NODI												
00400	pH	P - See Comments	0	--	Sample	=	6.88				=	7.36	12 - SU	05/WK - Five Per Week	GR - GRAB		
					Permit Req.	>=	6.5 INST MIN				<=	9.0 INST MAX	12 - SU	05/WK - Five Per Week	GR - GRAB		
					Value NODI												
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	220.0	=	229.0	26 - lb/d	=	2.91	=	3.03	19 - mg/L	02/07 - Twice Every Week	24 - COMP24
					Permit Req.	<=	2125.0 MO AVG	<=	3183.0 WKLY AVG	26 - lb/d	<=	30.0 MO AVG	<=	45.0 WKLY AVG	19 - mg/L	02/07 - Twice Every Week	24 - COMP24
					Value NODI												
00530	Solids, total suspended	G - Raw Sewage Influent	0	--	Sample						=	250.0		19 - mg/L	02/07 - Twice Every Week	24 - COMP24	
					Permit Req.						Req Mon MO AVG		19 - mg/L	02/07 - Twice Every Week	24 - COMP24		
					Value NODI												
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	0	--	Sample	=	5.75	=	39.3	26 - lb/d	=	0.08	=	0.31	19 - mg/L	02/07 - Twice Every Week	24 - COMP24
					Permit Req.	<=	110.0 MO AVG	<=	413.0 DAILY MX	26 - lb/d	<=	1.55 MO AVG	<=	5.83 DAILY MX	19 - mg/L	02/07 - Twice Every Week	24 - COMP24
					Value NODI												
00625	Nitrogen, Kjeldahl, total [as N]	1 - Effluent Gross	0	--	Sample						=	1.44	=	1.52	19 - mg/L	01/30 - Monthly	24 - COMP24
					Permit Req.						Req Mon MO AVG		19 - mg/L	01/30 - Monthly	24 - COMP24		
					Value NODI												
											=	14.55	=	15.9	19 - mg/L	01/30 - Monthly	24 - COMP24

