

					Value NODI																			
00665	Phosphorus, total [as P]	G - Raw Sewage Influent	0	--	Sample								=	4.61	=	4.61	19 - mg/L	01/30 - Monthly	24 - COMP24					
					Permit Req.									Req Mon MO AVG		Req Mon WKLY AVG	19 - mg/L	01/30 - Monthly	24 - COMP24					
					Value NODI																			
00671	Phosphate, ortho, dissolved [as P]	1 - Effluent Gross	0	--	Sample									=	2.07	=	2.07	19 - mg/L	01/30 - Monthly	24 - COMP24				
					Permit Req.										Req Mon MO AVG		Req Mon DAILY MX	19 - mg/L	01/30 - Monthly	24 - COMP24				
					Value NODI																			
00681	Carbon, dissolved organic [as C]	P - See Comments	0	--	Sample									=	5.36	=	5.36	19 - mg/L	01/30 - Monthly	24 - COMP24				
					Permit Req.										Req Mon MO AVG		Req Mon DAILY MX	19 - mg/L	01/30 - Monthly	24 - COMP24				
					Value NODI																			
00900	Hardness, total [as CaCO3]	P - See Comments	0	--	Sample									=	173.0	=	173.0	19 - mg/L	01/30 - Monthly	24 - COMP24				
					Permit Req.										Req Mon MO AVG		Req Mon DAILY MX	19 - mg/L	01/30 - Monthly	24 - COMP24				
					Value NODI																			
01119	Copper, total recoverable	P - See Comments	1	--	Sample									=	2.0	=	2.0	28 - ug/L	01/30 - Monthly	24 - COMP24				
					Permit Req.										Req Mon MO AVG		Req Mon DAILY MX	28 - ug/L	01/30 - Monthly	24 - COMP24				
					Value NODI																			
31648	E. coli, MTEC-MF	1 - Effluent Gross	0	--	Sample									=	1.0	=	1.0	13 - #/100mL	10/30 - Ten Per Month	GR - GRAB				
					Permit Req.									<=	126.0 MO GEOMN	<=	406.0 INST MAX	13 - #/100mL	10/30 - Ten Per Month	GR - GRAB				
					Value NODI																			
45613	Floating solids, waste or visible foam-visual	Q - See Comments	0	--	Sample				=	0.0										01/30 - Monthly	VI - VISUAL			
					Permit Req.				<=	0.0 MO MAX											01/30 - Monthly	VI - VISUAL		
					Value NODI																			
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample			=	9.6		=	15.19									99/99 - Continuous	RC - Recorder (auto)		
					Permit Req.				Req Mon MO AVG			Req Mon DAILY MX										99/99 - Continuous	RC - Recorder (auto)	
					Value NODI																			
81010	BOD, 5-day, percent removal	K - Percent Removal	0	--	Sample								=	96.13								23 - %	01/30 - Monthly	CA - CALCTD
					Permit Req.								>=	85.0 MO AV MN								23 - %	01/30 - Monthly	CA - CALCTD
					Value NODI																			
81011	Solids, suspended percent removal	K - Percent Removal	0	--	Sample								=	93.8								23 - %	01/30 - Monthly	CA - CALCTD
					Permit Req.								>=	85.0 MO AV MN								23 - %	01/30 - Monthly	CA - CALCTD
					Value NODI																			

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

No attachments.

Report Last Saved By
CALDWELL, CITY OF

User: MEASTMAN
 Name: Michael Eastman
 E-Mail: meastman@cityofcaldwell.org
 Date/Time: 2021-08-17 13:45 (Time Zone: -06:00)

Report Last Signed By

User: DHARMON@CITYOFCALDWELL.ORG
 Name: David Harmon
 E-Mail: dharmon@cityofcaldwell.org
 Date/Time: 2021-08-17 15:04 (Time Zone: -06:00)