

DMR Copy of Record

Permit		Permit #: ID0021504		Permittee: CALDWELL, CITY OF		Facility: CALDWELL, CITY OF - CALDWELL WWTP	
Major: Yes		Permittee Address: 621 E. CLEVELAND BLVD (MAILING ADDRESS) CALDWELL, ID 83605		Facility Location: 208 JOHNSON LANE CALDWELL, ID 83605			
Permitted Feature: REC External Outfall		Discharge: REC-A Boise River, Upstream					

Report Dates & Status		Monitoring Period: From 09/01/21 to 09/30/21		DMR Due Date: 10/20/21		Status: NetDMR Validated	
----------------------------------	--	---	--	-------------------------------	--	---------------------------------	--

Considerations for Form Completion
 Permit Part I.E. lists samples to be taken on the same day.

Principal Executive Officer		First Name: David		Title: WW Superintendent		Telephone: 208-477-4605	
		Last Name: Harmon					

No Data Indicator (NODI)
 Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type		
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units
X 00010	Temperature, water deg. centigrade	5 - Upstream Monitoring	0	--	Sample												04 - deg C	99/99 - Continuous	RC - Recorder (auto)
					Permit Req.						Req Mon MO AVG				Req Mon INST MAX				
					Value NODI						E - Failed to Sample/Required Analysis Not Conducted				E - Failed to Sample/Required Analysis Not Conducted				
00061	Stream flow, instantaneous	5 - Upstream Monitoring	0	--	Sample					=	189.0					08 - cfs	01/07 - Weekly	GR - GRAB	
					Permit Req.						Req Mon INST MIN				08 - cfs	01/07 - Weekly	GR - GRAB		
					Value NODI														
00070	Turbidity	5 - Upstream Monitoring	0	--	Sample									=	7.7	43 - NTU	01/07 - Weekly	GR - GRAB	
					Permit Req.									Req Mon INST MAX		43 - NTU	01/07 - Weekly	GR - GRAB	
					Value NODI														
00300	Oxygen, dissolved [DO]	5 - Upstream Monitoring	0	--	Sample					=	8.98					19 - mg/L	01/30 - Monthly	GR - GRAB	
					Permit Req.						Req Mon INST MIN					19 - mg/L	01/30 - Monthly	GR - GRAB	
					Value NODI														
00310	BOD, 5-day, 20 deg. C	5 - Upstream Monitoring	0	--	Sample									=	3.0	19 - mg/L	01/30 - Monthly	GR - GRAB	
					Permit Req.									Req Mon INST MAX		19 - mg/L	01/30 - Monthly	GR - GRAB	
					Value NODI														
00400	pH	5 - Upstream Monitoring	0	--	Sample					=	7.39				=	7.59	12 - SU	01/07 - Weekly	GR - GRAB
					Permit Req.						Req Mon INST MIN				Req Mon INST MAX		12 - SU	01/07 - Weekly	GR - GRAB
					Value NODI														
00600	Nitrogen, total [as N]	5 - Upstream Monitoring	0	--	Sample									=	2.54	19 - mg/L	01/30 - Monthly	GR - GRAB	
					Permit Req.									Req Mon INST MAX		19 - mg/L	01/30 - Monthly	GR - GRAB	
					Value NODI														
00665	Phosphorus, total [as P]	5 - Upstream Monitoring	0	--	Sample									=	130.0	28 - ug/L	01/30 - Monthly	GR - GRAB	
					Permit Req.									Req Mon INST MAX		28 - ug/L	01/30 - Monthly	GR - GRAB	
					Value NODI														
32230	Chlorophyll A	5 - Upstream Monitoring	0	--	Sample									=	0.01	28 - ug/L	01/30 - Monthly	GR - GRAB	
					Permit Req.									Req Mon INST MAX		28 - ug/L	01/30 - Monthly	GR - GRAB	
					Value NODI														

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

Parameter		Monitoring Location	Field	Type	Description	Acknowledge
Code	Name					
00010	Temperature, water deg. centigrade	5 - Upstream Monitoring	All	Soft	EPA's NPDES national data system recognizes the selected No Data Indicator (NODI) code as a reporting violation. NPDES permittees are responsible for ensuring full compliance with their permits, the Clean Water Act, and state law.	Yes

Comments

Upstream temperature was not collected due to USGS location equipment failure on 9/19/21. This caused our monthly temperature for this location to be incomplete. Used NODI Code E, as per James Craft. ME

Attachments

No attachments.

Report Last Saved By

CALDWELL, CITY OF

User: DHARMON@CITYOFCALDWELL.ORG
Name: David Harmon
E-Mail: dharmon@cityofcaldwell.org
Date/Time: 2021-10-14 12:41 (Time Zone: -06:00)

Report Last Signed By

User: DHARMON@CITYOFCALDWELL.ORG
Name: David Harmon
E-Mail: dharmon@cityofcaldwell.org
Date/Time: 2021-10-14 13:25 (Time Zone: -06:00)