



CITY OF
Caldwell, Idaho

GARRET NANCOLAS
Mayor

208.455.3011
(f) 208.455.3003

City Hall
411 Blaine Street
Caldwell, Idaho 83605

Post Office Box
P.O. Box 1179
Caldwell, Idaho 83606

For a list of the City
Council members, visit:
www.cityofcaldwell.com

James Craft
Compliance Officer
Idaho Department of Environmental Quality
Boise Regional Office
1445 North Orchard Street
Boise, Idaho 83706

December 22nd, 2021

Re: Sanitary Sewer Overflow

Dear Mr. Craft,

This purpose of this letter is to notify IDEQ of a sewer spill that occurred at the corner of Ash and Oregon street in Caldwell Idaho at approximately 11 am. The collections team was cleaning/jetting the sewer line when they observed liquid leaking from the rear of the vac. truck, upon inspection it was determined that the fill indicator was not working and the holding tank was over-full and leaked onto the ground. It was determined that approximately 15-20 gallons had leaked out. We immediately dispatched staff to the site with lime to clean the mess. The City of Caldwell Collections team will have the tank level indicator repaired before it goes to the street again.

Please feel free to contact us if you have any questions regarding this project. Thank you for your time and attention to this matter.

Sincerely,

Wastewater Superintendent