



# CITY OF *Caldwell, Idaho*

---

**GARRET NANCOLAS**  
*Mayor*

208.455.3011  
(f) 208.455.3003

**City Hall**  
411 Blaine Street  
Caldwell, Idaho 83605

**Post Office Box**  
P.O. Box 1179  
Caldwell, Idaho 83606

For a list of the City  
Council members, visit:  
[www.cityofcaldwell.com](http://www.cityofcaldwell.com)

James Craft  
Compliance Officer  
Idaho Department of Environmental Quality  
Boise Regional Office  
1445 North Orchard Street  
Boise, Idaho 83706

December 31st, 2021

Re: Sanitary Sewer Overflow

Dear Mr. Craft,

This purpose of this letter is to notify IDEQ of a sewer overflow that occurred at the Polk Street lift station at approximately 11pm December 30th. It was determined that the suction leg of the pump was plugged with grease. Approximately 1.5 to 3 gallons came out of the top and seeped onto the ground. We quickly spread lime onto the affected area and vac'd it up. The grease plug was cleared and the station is back to SOP.

Please feel free to contact us if you have any questions regarding this project. Thank you for your time and attention to this matter.

Sincerely,

Wastewater Superintendent