

DMR Copy of Record

<b>Permit</b>			
Permit #:	<b>ID0021504</b>	Permittee:	CALDWELL, CITY OF
Major:	Yes	Permittee Address:	621 E. CLEVELAND BLVD (MAILING ADDRESS) CALDWELL, ID 83605
Permitted Feature:	001 External Outfall	Discharge:	<b>001-A</b> Boise River
Facility:		Facility Location:	CALDWELL, CITY OF - CALDWELL WWTP 208 JOHNSON LANE CALDWELL, ID 83605

<b>Report Dates &amp; Status</b>			
Monitoring Period:	<b>From 11/01/21 to 11/30/21</b>	DMR Due Date:	<b>12/20/21</b>
Status:	<b>NetDMR Validated</b>		

**Considerations for Form Completion**  
P=Effluent, See Table 1, Note 10 for samples to be collected on the same day; Q=Effluent, full narrative description in Permit Part I.B.3.; R=Effluent, Table 1, note 7. Report Mo Inst Max, Max Daily Avg, 7 Day Running Avg of Daily Inst Max

<b>Principal Executive Officer</b>			
First Name:		Title:	
Last Name:		Telephone:	

**No Data Indicator (NODI)**  
Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type	
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3
00010	Temperature, water deg. centigrade	R - See Comments	0	--	Sample	=	19.37	=	19.12	=	19.56	04 - deg C	99/99 - Continuous	RC - Recorder (auto)				
					Permit Req.		Req Mon MX DA AV		Req Mon MX 7D AV		Req Mon INST MAX	04 - deg C						
					Value NODI													
00094	Conductivity	P - See Comments	0	--	Sample	=	732.0	=	793.0	11 - umho/cm	15	01/30 - Monthly	24 - COMP24					
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	11 - umho/cm								
					Value NODI													
00310	BOD, 5-day, 20 deg. C	1 - Effluent Gross	0	--	Sample	=	128.0	=	118.0	26 - lb/d	10	01/07 - Weekly	24 - COMP24					
					Permit Req.	<=	2127.0 MO AVG	<=	3190.0 WKLY AVG	26 - lb/d				<=	30.0 MO AVG	<=	45.0 WKLY AVG	19 - mg/L
					Value NODI													
00310	BOD, 5-day, 20 deg. C	G - Raw Sewage Influent	0	--	Sample	=	211.0			19 - mg/L	10	01/07 - Weekly	24 - COMP24					
					Permit Req.		Req Mon MO AVG			19 - mg/L								
					Value NODI													
00400	pH	P - See Comments	0	--	Sample	=	6.5			12 - SU	15	05/WK - Five Per Week	GR - GRAB					
					Permit Req.	>=	6.5 INST MIN			<=				9.0 INST MAX	12 - SU			
					Value NODI													
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	20.0	=	65.0	26 - lb/d	15	02/07 - Twice Every Week	24 - COMP24					
					Permit Req.	<=	2125.0 MO AVG	<=	3183.0 WKLY AVG	26 - lb/d				<=	30.0 MO AVG	<=	45.0 WKLY AVG	19 - mg/L
					Value NODI													
00530	Solids, total suspended	G - Raw Sewage Influent	0	--	Sample	=	341.0			19 - mg/L	15	02/07 - Twice Every Week	24 - COMP24					
					Permit Req.		Req Mon MO AVG			19 - mg/L								
					Value NODI													
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	1	--	Sample	=	5.23	=	17.4	26 - lb/d	15	01/07 - Weekly	24 - COMP24					
					Permit Req.	<=	191.0 MO AVG	<=	633.0 DAILY MX	26 - lb/d				<=	2.7 MO AVG	<=	8.93 DAILY MX	19 - mg/L
					Value NODI													
00625	Nitrogen, Kjeldahl, total [as N]	1 - Effluent Gross	0	--	Sample	=	2.48	=	2.48	19 - mg/L	1	01/30 - Monthly	24 - COMP24					
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	19 - mg/L								
					Value NODI													
00630	Nitrite + Nitrate total [as N]	1 - Effluent Gross	0	--	Sample	=	17.8	=	17.8	19 - mg/L	1	01/30 - Monthly	24 - COMP24					
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	19 - mg/L								
					Value NODI													

