

DMR Copy of Record

Permit			
Permit #:	ID0021504	Permittee:	CALDWELL, CITY OF
Major:	Yes	Permittee Address:	621 E. CLEVELAND BLVD (MAILING ADDRESS) CALDWELL, ID 83605
Permitted Feature:	REC External Outfall	Discharge:	REC-B Boise River, Downstream
Facility:	CALDWELL, CITY OF - CALDWELL WWTP		
Facility Location:	208 JOHNSON LANE CALDWELL, ID 83605		

Report Dates & Status			
Monitoring Period:	From 12/01/21 to 12/31/21	DMR Due Date:	01/20/22
Status:	NetDMR Validated		

Considerations for Form Completion
Permit Part I.E lists samples to be taken on the same day.

Principal Executive Officer			
First Name:	David	Title:	WW Superintendent
Last Name:	Harmon	Telephone:	208-477-4605

No Data Indicator (NODI)
Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading				Quality or Concentration				# of Ex.	Frequency of Analysis	Sample Type										
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2				Value 2	Qualifier 3	Value 3	Units						
00010	Temperature, water deg. centigrade	6 - Downstream Monitoring	0	--	Sample							=	7.61		=	10.1	04 - deg C	99/99 - Continuous	RC - Recorder (auto)						
					Permit Req.												Req Mon MO AVG			Req Mon INST MAX	04 - deg C				
					Value NODI																				
00070	Turbidity	6 - Downstream Monitoring	0	--	Sample										=	3.8	43 - NTU	4	01/07 - Weekly	03 - COMP-3					
					Permit Req.																		Req Mon INST MAX	43 - NTU	
					Value NODI																				
00400	pH	6 - Downstream Monitoring	0	--	Sample							=	7.3			=	7.4	12 - SU	4	01/07 - Weekly	03 - COMP-3				
					Permit Req.																		Req Mon INST MIN	Req Mon INST MAX	12 - SU
					Value NODI																				
00600	Nitrogen, total [as N]	6 - Downstream Monitoring	0	--	Sample											=	3.62	19 - mg/L	1	01/30 - Monthly	03 - COMP-3				
					Permit Req.																		Req Mon INST MAX	19 - mg/L	
					Value NODI																				
00665	Phosphorus, total [as P]	6 - Downstream Monitoring	0	--	Sample											=	133.0	28 - ug/L	1	01/30 - Monthly	03 - COMP-3				
					Permit Req.																		Req Mon INST MAX	28 - ug/L	
					Value NODI																				
00900	Hardness, total [as CaCO3]	6 - Downstream Monitoring	0	--	Sample											=	113.0	19 - mg/L	1	01/30 - Monthly	03 - COMP-3				
					Permit Req.																		Req Mon INST MAX	19 - mg/L	
					Value NODI																				
32230	Chlorophyll A	6 - Downstream Monitoring	0	--	Sample											=	0.011	28 - ug/L	1	01/30 - Monthly	03 - COMP-3				
					Permit Req.																		Req Mon INST MAX	28 - ug/L	
					Value NODI																				

Submission Note
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors
No errors.

Comments
done

Attachments
No attachments.

Report Last Saved By
CALDWELL, CITY OF

User: DHARMON@CITYOFCALDWELL.ORG
Name: David Harmon
E-Mail: dharmon@cityofcaldwell.org
Date/Time: 2022-01-19 07:44 (Time Zone: -07:00)

Report Last Signed By
User: DHARMON@CITYOFCALDWELL.ORG

Name: David Harmon
E-Mail: dharmon@cityofcaldwell.org
Date/Time: 2022-01-19 07:44 (Time Zone: -07:00)