

DMR Copy of Record

<b>Permit</b>		<b>Permit #:</b> ID0021504		<b>Permittee:</b> CALDWELL, CITY OF		<b>Facility:</b> CALDWELL, CITY OF - CALDWELL WWTP	
<b>Major:</b> Yes		<b>Permittee Address:</b> 621 E. CLEVELAND BLVD (MAILING ADDRESS) CALDWELL, ID 83605		<b>Facility Location:</b> 208 JOHNSON LANE CALDWELL, ID 83605			
<b>Permitted Feature:</b> 001 External Outfall		<b>Discharge:</b> 001-A Boise River					

<b>Report Dates &amp; Status</b>			
<b>Monitoring Period:</b> From 10/01/22 to 10/31/22	<b>DMR Due Date:</b> 11/20/22	<b>Status:</b> NetDMR Validated	

**Considerations for Form Completion**  
P=Effluent, See Table 1, Note 10 for samples to be collected on the same day; Q=Effluent, full narrative description in Permit Part I.B.3.; R=Effluent, Table 1, note 7. Report Mo Inst Max, Max Daily Avg, 7 Day Running Avg of Daily Inst Max

<b>Principal Executive Officer</b>		<b>Title:</b> Assistant Superintendent		<b>Telephone:</b> 208-550-6313	
<b>First Name:</b> Gustav	<b>Last Name:</b> Betterley				

**No Data Indicator (NODI)**  
Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type	
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3
00010	Temperature, water deg. centigrade	R - See Comments	0	--	Sample	=	20.3	=	20.3	=	19.8	04 - deg C	17	99/99 - Continuous	RC - Recorder (auto)			
					Permit Req.		Req Mon MX DA AV		Req Mon MX 7D AV		Req Mon INST MAX	04 - deg C			RC - Recorder (auto)			
					Value NODI													
00094	Conductivity	P - See Comments	0	--	Sample	=	803.0	=	838.0	11 - umho/cm	17	01/30 - Monthly	24 - COMP24					
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	11 - umho/cm			24 - COMP24					
					Value NODI													
00310	BOD, 5-day, 20 deg. C	1 - Effluent Gross	0	--	Sample	=	191.0	=	197.0	26 - lb/d	12	01/07 - Weekly	24 - COMP24					
					Permit Req.	<=	2127.0 MO AVG	<=	3190.0 WKLY AVG	26 - lb/d			<=	30.0 MO AVG	<=	45.0 WKLY AVG	19 - mg/L	24 - COMP24
					Value NODI													
00310	BOD, 5-day, 20 deg. C	G - Raw Sewage Influent	0	--	Sample	=	237.0			19 - mg/L	12	01/07 - Weekly	24 - COMP24					
					Permit Req.		Req Mon MO AVG			19 - mg/L			24 - COMP24					
					Value NODI													
00400	pH	P - See Comments	0	--	Sample	=	6.7			12 - SU	21	05/WK - Five Per Week	GR - GRAB					
					Permit Req.	>=	6.5 INST MIN			<=			9.0 INST MAX	12 - SU	GR - GRAB			
					Value NODI													
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	245.0	=	233.0	26 - lb/d	17	02/07 - Twice Every Week	24 - COMP24					
					Permit Req.	<=	2125.0 MO AVG	<=	3183.0 WKLY AVG	26 - lb/d			<=	30.0 MO AVG	<=	45.0 WKLY AVG	19 - mg/L	24 - COMP24
					Value NODI													
00530	Solids, total suspended	G - Raw Sewage Influent	0	--	Sample	=	318.0			19 - mg/L	17	02/07 - Twice Every Week	24 - COMP24					
					Permit Req.		Req Mon MO AVG			19 - mg/L			24 - COMP24					
					Value NODI													
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	1	--	Sample	=	16.4	=	14.4	26 - lb/d	17	01/07 - Weekly	24 - COMP24					
					Permit Req.	<=	191.0 MO AVG	<=	633.0 DAILY MX	26 - lb/d			<=	2.7 MO AVG	<=	8.93 DAILY MX	19 - mg/L	24 - COMP24
					Value NODI													
00625	Nitrogen, Kjeldahl, total [as N]	1 - Effluent Gross	0	--	Sample	=	1.97	=	1.97	19 - mg/L	11	01/30 - Monthly	24 - COMP24					
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	19 - mg/L			24 - COMP24					
					Value NODI													
00630	Nitrite + Nitrate total [as N]	1 - Effluent Gross	0	--	Sample	=	18.2	=	18.2	19 - mg/L	1	01/30 - Monthly	24 - COMP24					
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	19 - mg/L			24 - COMP24					
					Value NODI													

