

DMR Copy of Record

Permit					
Permit #:	ID0021504	Permittee:	CALDWELL, CITY OF	Facility:	CALDWELL, CITY OF - CALDWELL WWTP
Major:	Yes	Permittee Address:	621 E. CLEVELAND BLVD (MAILING ADDRESS) CALDWELL, ID 83605	Facility Location:	208 JOHNSON LANE CALDWELL, ID 83605
Permitted Feature:	001 External Outfall	Discharge:	001-A Boise River		

Report Dates & Status					
Monitoring Period:	From 12/01/22 to 12/31/22	DMR Due Date:	01/20/23	Status:	NetDMR Validated

Considerations for Form Completion
P=Effluent, See Table 1, Note 10 for samples to be collected on the same day; Q=Effluent, full narrative description in Permit Part I.B.3.; R=Effluent, Table 1, note 7. Report Mo Inst Max, Max Daily Avg, 7 Day Running Avg of Daily Inst Max

Principal Executive Officer					
First Name:	David	Title:	WW Superintendent	Telephone:	208-477-4605
Last Name:	Harmon				

No Data Indicator (NODI)
Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3			
00010	Temperature, water deg. centigrade	R - See Comments	0	--	Sample	=	16.1	=	15.9	=	16.3	04 - deg C	12	99/99 - Continuous	RC - Recorder (auto)		
					Permit Req.		Req Mon MX DA AV		Req Mon MX 7D AV		Req Mon INST MAX	04 - deg C					
					Value NODI												
00094	Conductivity	P - See Comments	0	--	Sample	=	787.0	=	860.0	11 - umho/cm	12	01/30 - Monthly	24 - COMP24				
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	11 - umho/cm							
					Value NODI												
00310	BOD, 5-day, 20 deg. C	1 - Effluent Gross	0	--	Sample	=	222.0	=	220.0	26 - lb/d	12	01/07 - Weekly	24 - COMP24				
					Permit Req.	<=	2127.0 MO AVG	<=	3190.0 WKLY AVG	26 - lb/d							
					Value NODI												
00310	BOD, 5-day, 20 deg. C	G - Raw Sewage Influent	0	--	Sample	=	238.0		19 - mg/L	12	01/07 - Weekly	24 - COMP24					
					Permit Req.		Req Mon MO AVG		19 - mg/L								
					Value NODI												
00400	pH	P - See Comments	0	--	Sample	=	6.7	=	7.0	12 - SU	22	05/WK - Five Per Week	GR - GRAB				
					Permit Req.	>=	6.5 INST MIN		<=	9.0 INST MAX				12 - SU			
					Value NODI												
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	312.0	=	297.0	26 - lb/d	16	02/07 - Twice Every Week	24 - COMP24				
					Permit Req.	<=	2125.0 MO AVG	<=	3183.0 WKLY AVG	26 - lb/d							
					Value NODI												
00530	Solids, total suspended	G - Raw Sewage Influent	0	--	Sample	=	282.0		19 - mg/L	16	02/07 - Twice Every Week	24 - COMP24					
					Permit Req.		Req Mon MO AVG		19 - mg/L								
					Value NODI												
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	1	--	Sample	=	1.0	=	1.07	26 - lb/d	1	01/07 - Weekly	24 - COMP24				
					Permit Req.	<=	191.0 MO AVG	<=	633.0 DAILY MX	26 - lb/d							
					Value NODI												
00625	Nitrogen, Kjeldahl, total [as N]	1 - Effluent Gross	0	--	Sample	=	1.58	=	1.58	19 - mg/L	1	01/30 - Monthly	24 - COMP24				
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	19 - mg/L							
					Value NODI												
00630	Nitrite + Nitrate total [as N]	1 - Effluent Gross	0	--	Sample	=	19.5	=	19.5	19 - mg/L	1	01/30 - Monthly	24 - COMP24				
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	19 - mg/L							
					Value NODI												

