DMR Copy of Record

Permit					
Permit #:	**ID0021504**	**Permittee:**	CALDWELL, CITY OF	**Facility:**	CALDWELL, CITY OF - CALDWELL WWTP
Major:	Yes	**Permittee Address:**	621 E. CLEVELAND BLVD (MAILING ADDRESS) CALDWELL, ID 83605	**Facility Location:**	208 JOHNSON LANE CALDWELL, ID 83605
Permitted Feature:	001 External Outfall	**Discharge:**	**001-E** Boise River		
Report Dates & Status					
Monitoring Period:	**From 04/01/22 to 03/31/23**	**DMR Due Date:**	**04/20/23**	**Status:**	**NetDMR Validated**
Considerations for Form Completion					
Permit Table 1, Note 3 gives sampling procedures; report on March DMR; P=Influent; Permit Part I.B.8 gives sampling procedures; Q=Effluent; Permit Part I.B.8 gives sampling procedures					
Principal Executive Officer					
First Name:	Gustav	**Title:**	Assistant Superintendent	**Telephone:**	208-550-6313
Last Name:	Betterley				
No Data Indicator (NODI)					
Form NODI:	--				

Parameter		Monitoring Location	Season #	Param. NODI		Quantity or Loading					Quality or Concentration							# of Ex.	Frequency of Analysis	Sample Type
Code	Name					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units			
00718	**Cyanide, weak acid, dissociable**	P - See Comments	0	--	Sample								<	5.0	<	5.0	28 - ug/L	3	01/YR - Annual	CG - CMPGRB
					Permit Req.									Req Mon MO AVG		Req Mon INST MAX	28 - ug/L		01/YR - Annual	CG - CMPGRB
					Value NODI															
00718	**Cyanide, weak acid, dissociable**	Q - See Comments	0	--	Sample								<	5.0	<	5.0	28 - ug/L	3	01/YR - Annual	CG - CMPGRB
					Permit Req.									Req Mon MO AVG		Req Mon INST MAX	28 - ug/L		01/YR - Annual	CG - CMPGRB
					Value NODI															
00978	**Arsenic, total recoverable**	1 - Effluent Gross	0	--	Sample								=	7.93	=	8.1	28 - ug/L	3	01/YR - Annual	24 - COMP24
					Permit Req.									Req Mon MO AVG		Req Mon INST MAX	28 - ug/L		01/YR - Annual	24 - COMP24
					Value NODI															
00978	**Arsenic, total recoverable**	G - Raw Sewage Influent	0	--	Sample								=	9.63	=	10.1	28 - ug/L	3	01/YR - Annual	24 - COMP24
					Permit Req.									Req Mon MO AVG		Req Mon INST MAX	28 - ug/L		01/YR - Annual	24 - COMP24
					Value NODI															
00981	**Selenium, total recoverable**	1 - Effluent Gross	0	--	Sample								<	1.0	<	1.0	28 - ug/L	3	01/YR - Annual	24 - COMP24
					Permit Req.									Req Mon MO AVG		Req Mon INST MAX	28 - ug/L		01/YR - Annual	24 - COMP24
					Value NODI															
00981	**Selenium, total recoverable**	G - Raw Sewage Influent	0	--	Sample								=	1.2	=	1.3	28 - ug/L	3	01/YR - Annual	24 - COMP24
					Permit Req.									Req Mon MO AVG		Req Mon INST MAX	28 - ug/L		01/YR - Annual	24 - COMP24
					Value NODI															
01074	**Nickel, total recoverable**	1 - Effluent Gross	0	--	Sample								=	0.67	=	0.7	28 - ug/L	3	01/YR - Annual	24 - COMP24
					Permit Req.									Req Mon MO AVG		Req Mon INST MAX	28 - ug/L		01/YR - Annual	24 - COMP24
					Value NODI															
01074	**Nickel, total recoverable**	G - Raw Sewage Influent	0	--	Sample								=	7.77	=	12.5	28 - ug/L	3	01/YR - Annual	24 - COMP24
					Permit Req.									Req Mon MO AVG		Req Mon INST MAX	28 - ug/L		01/YR - Annual	24 - COMP24
					Value NODI															
01079	**Silver total recoverable**	1 - Effluent Gross	0	--	Sample								<	0.2	<	0.2	28 - ug/L	3	01/YR - Annual	24 - COMP24
					Permit Req.									Req Mon MO AVG		Req Mon INST MAX	28 - ug/L		01/YR - Annual	24 - COMP24
					Value NODI															
01079	**Silver total recoverable**	G - Raw Sewage Influent	0	--	Sample								<	0.2	=	0.2	28 - ug/L	3	01/YR - Annual	24 - COMP24
					Permit Req.									Req Mon MO AVG		Req Mon INST MAX	28 - ug/L		01/YR - Annual	24 - COMP24
					Value NODI															
01094	**Zinc, total recoverable**	1 - Effluent Gross	0	--	Sample								=	23.7	=	25.0	28 - ug/L	3	01/YR - Annual	24 - COMP24
					Permit Req.									Req Mon MO AVG		Req Mon INST MAX	28 - ug/L		01/YR - Annual	24 - COMP24
					Value NODI															
01094	**Zinc, total recoverable**	G - Raw Sewage Influent	0	--	Sample								=	104.7	=	149.0	28 - ug/L	3	01/YR - Annual	24 - COMP24
					Permit Req.									Req Mon MO AVG		Req Mon INST MAX	28 - ug/L		01/YR - Annual	24 - COMP24
					Value NODI															
01113	**Cadmium, total recoverable**	1 - Effluent Gross	0	--	Sample								<	0.1	<	0.1	28 - ug/L	3	01/YR - Annual	24 - COMP24
					Permit Req.									Req Mon MO AVG		Req Mon INST MAX	28 - ug/L		01/YR - Annual	24 - COMP24

					Value NODI															
01113	**Cadmium, total recoverable**	G - Raw Sewage Influent	0	--	Sample							=	0.17	=	0.2	28 - ug/L	3	01/YR - Annual	24 - COMP24
					Permit Req.								Req Mon MO AVG		Req Mon INST MAX	28 - ug/L		01/YR - Annual	24 - COMP24
					Value NODI														
01114	**Lead, total recoverable**	1 - Effluent Gross	0	--	Sample							<	1.97	=	3.0	28 - ug/L	3	01/YR - Annual	24 - COMP24
					Permit Req.								Req Mon MO AVG		Req Mon INST MAX	28 - ug/L		01/YR - Annual	24 - COMP24
					Value NODI														
01114	**Lead, total recoverable**	G - Raw Sewage Influent	0	--	Sample							=	8.87	=	12.6	28 - ug/L	3	01/YR - Annual	24 - COMP24
					Permit Req.								Req Mon MO AVG		Req Mon INST MAX	28 - ug/L		01/YR - Annual	24 - COMP24
					Value NODI														
01118	**Chromium, total recoverable**	1 - Effluent Gross	0	--	Sample							=	1.13	=	1.2	28 - ug/L	3	01/YR - Annual	24 - COMP24
					Permit Req.								Req Mon MO AVG		Req Mon INST MAX	28 - ug/L		01/YR - Annual	24 - COMP24
					Value NODI														
01118	**Chromium, total recoverable**	G - Raw Sewage Influent	0	--	Sample							=	4.7	=	12.1	28 - ug/L	3	01/YR - Annual	24 - COMP24
					Permit Req.								Req Mon MO AVG		Req Mon INST MAX	28 - ug/L		01/YR - Annual	24 - COMP24
					Value NODI														
01119	**Copper, total recoverable**	G - Raw Sewage Influent	0	--	Sample							<	2.0	<	2.0	28 - ug/L	3	01/YR - Annual	24 - COMP24
					Permit Req.								Req Mon MO AVG		Req Mon INST MAX	28 - ug/L		01/YR - Annual	24 - COMP24
					Value NODI														
01129	**Molybdenum, total recoverable**	1 - Effluent Gross	0	--	Sample							=	4.0	=	4.2	28 - ug/L	3	01/YR - Annual	24 - COMP24
					Permit Req.								Req Mon MO AVG		Req Mon INST MAX	28 - ug/L		01/YR - Annual	24 - COMP24
					Value NODI														
01129	**Molybdenum, total recoverable**	G - Raw Sewage Influent	0	--	Sample							=	6.1	=	5.6	28 - ug/L	3	01/YR - Annual	24 - COMP24
					Permit Req.								Req Mon MO AVG		Req Mon INST MAX	28 - ug/L		01/YR - Annual	24 - COMP24
					Value NODI														
01220	**Chromium, hexavalent dissolved [as Cr]**	1 - Effluent Gross	0	--	Sample							<	5.0	<	5.0	28 - ug/L	3	01/YR - Annual	24 - COMP24
					Permit Req.								Req Mon MO AVG		Req Mon INST MAX	28 - ug/L		01/YR - Annual	24 - COMP24
					Value NODI														
01220	**Chromium, hexavalent dissolved [as Cr]**	G - Raw Sewage Influent	0	--	Sample							<	5.5	=	6.5	28 - ug/L	3	01/YR - Annual	24 - COMP24
					Permit Req.								Req Mon MO AVG		Req Mon INST MAX	28 - ug/L		01/YR - Annual	24 - COMP24
					Value NODI														
71901	**Mercury, total recoverable**	G - Raw Sewage Influent	0	--	Sample							=	0.0012	=	0.0025	28 - ug/L	3	01/YR - Annual	24 - COMP24
					Permit Req.								Req Mon MO AVG		Req Mon INST MAX	28 - ug/L		01/YR - Annual	24 - COMP24
					Value NODI														

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Reviewed 4-17-23. GJB

Attachments

No attachments.

Report Last Saved By

CALDWELL, CITY OF

User:	GBETTERLEY@CITYOFCALDWELL.ORG
Name:	Gustav Betterley
E-Mail:	gbetterley@cityofcaldwell.org
Date/Time:	2023-04-17 09:34 (Time Zone: -06:00)

Report Last Signed By

User:	GBETTERLEY@CITYOFCALDWELL.ORG
Name:	Gustav Betterley
E-Mail:	gbetterley@cityofcaldwell.org
Date/Time:	2023-04-17 09:34 (Time Zone: -06:00)