

					Value NODI													
01113	Cadmium, total recoverable	G - Raw Sewage Influent	0	--	Sample	=	0.32	=	2.48	28 - ug/L	01/YR - Annual	24 - COMP24						
					Permit Req.		Req Mon MO AVG		Req Mon INST MAX	28 - ug/L	0	01/YR - Annual	24 - COMP24					
					Value NODI													
01114	Lead, total recoverable	1 - Effluent Gross	0	--	Sample	=	0.44	=	23.98	28 - ug/L	01/YR - Annual	24 - COMP24						
					Permit Req.		Req Mon MO AVG		Req Mon INST MAX	28 - ug/L	0	01/YR - Annual	24 - COMP24					
					Value NODI													
01114	Lead, total recoverable	G - Raw Sewage Influent	0	--	Sample	=	3.03	=	33.74	28 - ug/L	01/YR - Annual	24 - COMP24						
					Permit Req.		Req Mon MO AVG		Req Mon INST MAX	28 - ug/L	0	01/YR - Annual	24 - COMP24					
					Value NODI													
01118	Chromium, total recoverable	1 - Effluent Gross	0	--	Sample	=	1.39	=	8.28	28 - ug/L	01/YR - Annual	24 - COMP24						
					Permit Req.		Req Mon MO AVG		Req Mon INST MAX	28 - ug/L	0	01/YR - Annual	24 - COMP24					
					Value NODI													
01118	Chromium, total recoverable	G - Raw Sewage Influent	0	--	Sample	=	5.13	=	13.67	28 - ug/L	01/YR - Annual	24 - COMP24						
					Permit Req.		Req Mon MO AVG		Req Mon INST MAX	28 - ug/L	0	01/YR - Annual	24 - COMP24					
					Value NODI													
01119	Copper, total recoverable	G - Raw Sewage Influent	0	--	Sample	=	56.75	=	186.85	28 - ug/L	01/YR - Annual	24 - COMP24						
					Permit Req.		Req Mon MO AVG		Req Mon INST MAX	28 - ug/L	0	01/YR - Annual	24 - COMP24					
					Value NODI													
01129	Molybdenum, total recoverable	1 - Effluent Gross	0	--	Sample	=	3.81	=	5.79	28 - ug/L	01/YR - Annual	24 - COMP24						
					Permit Req.		Req Mon MO AVG		Req Mon INST MAX	28 - ug/L		01/YR - Annual	24 - COMP24					
					Value NODI													
01129	Molybdenum, total recoverable	G - Raw Sewage Influent	0	--	Sample	=	5.98	=	13.6	28 - ug/L	01/YR - Annual	24 - COMP24						
					Permit Req.		Req Mon MO AVG		Req Mon INST MAX	28 - ug/L		01/YR - Annual	24 - COMP24					
					Value NODI													
01220	Chromium, hexavalent dissolved [as Cr]	1 - Effluent Gross	0	--	Sample	=	0.01	=	0.01	28 - ug/L	01/YR - Annual	24 - COMP24						
					Permit Req.		Req Mon MO AVG		Req Mon INST MAX	28 - ug/L		01/YR - Annual	24 - COMP24					
					Value NODI													
01220	Chromium, hexavalent dissolved [as Cr]	G - Raw Sewage Influent	0	--	Sample	=	0.04	=	0.11	28 - ug/L	01/YR - Annual	24 - COMP24						
					Permit Req.		Req Mon MO AVG		Req Mon INST MAX	28 - ug/L		01/YR - Annual	24 - COMP24					
					Value NODI													
71901	Mercury, total recoverable	G - Raw Sewage Influent	0	--	Sample	=	0.16	=	0.2	28 - ug/L	01/YR - Annual	24 - COMP24						
					Permit Req.		Req Mon MO AVG		Req Mon INST MAX	28 - ug/L		01/YR - Annual	24 - COMP24					
					Value NODI													

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Reviewed. GJB

Attachments

No attachments.

Report Last Saved By

CALDWELL, CITY OF

User: GBETTERLEY@CITYOFCALDWELL.ORG

Name: Gustav Betterley

E-Mail: gbetterley@cityofcaldwell.org

Date/Time: 2024-04-11 11:26 (Time Zone: -06:00)

Report Last Signed By

User: GBETTERLEY@CITYOFCALDWELL.ORG

Name: Gustav Betterley

E-Mail: gbetterley@cityofcaldwell.org

Date/Time: 2024-04-17 10:57 (Time Zone: -06:00)