

00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	1	--	Sample Permit Req. Value NODI	=	22.9	191.0 MO AVG	<=	225.9	26 - lb/d	26 - lb/d	633.0 DAILY MX	26 - lb/d	19 - mg/L	2.9	8.93 DAILY MX	19 - mg/L	0	01/07 - Weekly	24 - COMP24
00625	Nitrogen, Kjeldahl, total [as N]	1 - Effluent Gross	0	--	Sample Permit Req. Value NODI	=									19 - mg/L	2.9	Req Mon DAILY MX	19 - mg/L	0	01/30 - Monthly	24 - COMP24
00630	Nitrite + Nitrate total [as N]	1 - Effluent Gross	0	--	Sample Permit Req. Value NODI	=									19 - mg/L	12.0	Req Mon DAILY MX	19 - mg/L	0	01/30 - Monthly	24 - COMP24
00685	Phosphorus, total [as P]	G - Raw Sewage Influent	0	--	Sample Permit Req. Value NODI	=									19 - mg/L	4.32	Req Mon WKLY AVG	19 - mg/L	0	01/30 - Monthly	24 - COMP24
00671	Phosphate, ortho, dissolved [as P]	1 - Effluent Gross	0	--	Sample Permit Req. Value NODI	=									19 - mg/L	0.76	Req Mon MO AVG	19 - mg/L	0	01/30 - Monthly	24 - COMP24
00681	Carbon, dissolved organic [as C]	P - See Comments	0	--	Sample Permit Req. Value NODI	=									19 - mg/L	6.2	Req Mon DAILY MX	19 - mg/L	0	01/30 - Monthly	24 - COMP24
00900	Hardness, total [as CaCO3]	P - See Comments	0	--	Sample Permit Req. Value NODI	=									19 - mg/L	190.5	Req Mon MO AVG	19 - mg/L	0	01/30 - Monthly	24 - COMP24
01119	Copper, total recoverable	P - See Comments	1	--	Sample Permit Req. Value NODI	=									28 - ug/L	7.1	Req Mon DAILY MX	28 - ug/L	0	01/30 - Monthly	24 - COMP24
31648	E. coli, MTEC-MF	1 - Effluent Gross	0	--	Sample Permit Req. Value NODI	=									13 - #/100mL	7.5	466.0 INST MAX	13 - #/100mL	0	10/30 - Ten Per Month	GR - GRAB
46513	Floating solids, waste or visible foam-visual	Q - See Comments	0	--	Sample Permit Req. Value NODI	=									9P - N=CY=1	0.0	0.0 MO MAX				VI - VISUAL
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample Permit Req. Value NODI	=									9P - N=CY=1	9.5	Req Mon MO AVG	9.9	Req Mon DAILY MX	03 - MGD	RC - Recorder (auto)
81010	BOD, 5-day, percent removal	K - Percent Removal	0	--	Sample Permit Req. Value NODI	=									88.6	85.0 MO AV MN		23 - %	0	01/30 - Monthly	CA - CALCTD
81011	Solids, suspended percent removal	K - Percent Removal	0	--	Sample Permit Req. Value NODI	=									88.3	85.0 MO AV MN		23 - %	0	01/30 - Monthly	CA - CALCTD

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Reviewed: 9-19-24 GJB

Attachments

No attachments.

Report Last Saved By

CALDWELL, CITY OF

User: GBETTERLEY@CITYOFCALDWELL.ORG
Name: Gustav Betterley
E-Mail: gbetterley@cityofcaldwell.org
Date/Time: 2024-09-19 10:41 (Time Zone: -06:00)

Report Last Signed By

User: GBETTERLEY@CITYOFCALDWELL.ORG
Name: Gustav Betterley
E-Mail: gbetterley@cityofcaldwell.org
Date/Time: 2024-09-19 13:06 (Time Zone: -06:00)