

00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	1	<	7.5	=	40.2	26 - lb/d	26 - lb/d	<=	0.1	=	0.5	19 - mg/L	01/07 - Weekly	24 - COMP24
				<=	191.0 MO AVG	<=	633.0 DAILY MX				<=	2.7 MO AVG	<=	8.93 DAILY MX	0	24 - COMP24
00625	Nitrogen, Kjeldahl, total [as N]	1 - Effluent Gross	0	=							=	2.2	19 - mg/L	01/30 - Monthly	24 - COMP24	
												Req Mon, MO AVG	Req Mon DAILY MX	0	24 - COMP24	
00630	Nitrite + Nitrate total [as N]	1 - Effluent Gross	0	=							=	14.8	19 - mg/L	01/30 - Monthly	24 - COMP24	
												Req Mon, MO AVG	Req Mon DAILY MX	0	24 - COMP24	
00685	Phosphorus, total [as P]	G - Raw Sewage Influent	0	=							=	4.3	19 - mg/L	01/30 - Monthly	24 - COMP24	
												Req Mon, MO AVG	Req Mon WKLY AVG	0	24 - COMP24	
00671	Phosphate, ortho, dissolved [as P]	1 - Effluent Gross	0	=							=	1.3	19 - mg/L	01/30 - Monthly	24 - COMP24	
												Req Mon, MO AVG	Req Mon DAILY MX	0	24 - COMP24	
00681	Carbon, dissolved organic [as C]	P - See Comments	0	=							=	4.4	19 - mg/L	01/30 - Monthly	24 - COMP24	
												Req Mon, MO AVG	Req Mon DAILY MX	0	24 - COMP24	
00900	Hardness, total [as CaCO3]	P - See Comments	0	=							=	184.9	19 - mg/L	01/30 - Monthly	24 - COMP24	
												Req Mon, MO AVG	Req Mon DAILY MX	0	24 - COMP24	
01119	Copper, total recoverable	P - See Comments	1	=							=	3.3	28 - ug/L	01/30 - Monthly	24 - COMP24	
												Req Mon, MO AVG	Req Mon DAILY MX	0	24 - COMP24	
31648	E. coli, MTEC-MF	1 - Effluent Gross	0	=							=	1.5	13 - #/100mL	10/30 - Ten Per Month	GR - GRAB	
												126.0 MO GEOMN	466.0 INST MAX	0	GR - GRAB	
46513	Floating solids, waste or visible foam-visual	Q - See Comments	0	=											VI - VISUAL	
															VI - VISUAL	
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	=	9.5		10.1	03 - MGD	03 - MGD						RC - Recorder (auto)	
					Req Mon, MO AVG	Req Mon, MO MX									RC - Recorder (auto)	
81010	BOD, 5-day, percent removal	K - Percent Removal	0	=							=	98.8	23 - %	01/30 - Monthly	CA - CALCTD	
												>=	85.0 MO AV MN	0	CA - CALCTD	
81011	Solids, suspended percent removal	K - Percent Removal	0	=							=	98.6	23 - %	01/30 - Monthly	CA - CALCTD	
												>=	85.0 MO AV MN	0	CA - CALCTD	

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Reviewed: GJB

Attachments

No attachments.

Report Last Saved By

CALDWELL, CITY OF

User: GBETTERLEY@CITYOFCALDWELL.ORG
Name: Gustav Betterley
E-Mail: gbetterley@cityofcaldwell.org
Date/Time: 2024-10-15 09:28 (Time Zone: -06:00)

Report Last Signed By

User: GBETTERLEY@CITYOFCALDWELL.ORG
Name: Gustav Betterley
E-Mail: gbetterley@cityofcaldwell.org
Date/Time: 2024-10-15 09:28 (Time Zone: -06:00)