



CITY OF  
*Caldwell, Idaho*

---

**GARRET NANCOLAS**  
*Mayor*

208.455.3011  
(f) 208.455.3003

**City Hall**  
411 Blaine Street  
Caldwell, Idaho 83605

**Post Office Box**  
P.O. Box 1179  
Caldwell, Idaho 83606

For a list of the City  
Council members, visit:  
**Website**  
[www.cityofcaldwell.com](http://www.cityofcaldwell.com)

12-2-16

The cooling fan system for the UV tripped out and overheated at 0845 – 0900 hours. Approximately 67,695 gallons went untreated to the Boise River. The system was immediately reset and an electrician is coming out to troubleshoot to ensure that this problem does not reoccur. Samples were taken and are being sent to Analytical Laboratories. If you have any questions, please contact me directly at 208-899-0902. This is our written notification.

Sincerely,

Salvador Arreola  
Wastewater Treatment Plant Superintendent