

45613	Floating solids, waste or visible foam-visual	Q - See Comments	0	--	Sample	=	0	9P - N=0;Y=1							01/30 - Monthly	VI - VISUAL
					Permit Req.	<=	0 MO MAX	9P - N=0;Y=1							01/30 - Monthly	VI - VISUAL
					Value NODI											
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	5.992	=	6.703	03 - MGD					99/99 - Continuous	RC - Recorder (auto)
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	03 - MGD					99/99 - Continuous	RC - Recorder (auto)
					Value NODI											
81010	BOD, 5-day, percent removal	K - Percent Removal	0	--	Sample	=				97					01/30 - Monthly	CA - CALCTD
					Permit Req.					>=	85 MO AV MN				01/30 - Monthly	CA - CALCTD
					Value NODI											
81011	Solids, suspended percent removal	K - Percent Removal	0	--	Sample	=				97					01/30 - Monthly	CA - CALCTD
					Permit Req.					>=	85 MO AV MN				01/30 - Monthly	CA - CALCTD
					Value NODI											

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

Name	Type	Size
2018_02_Lab_Statement_WWTP.pdf	pdf	1387745
2018_02_Lab_Statement.pdf	pdf	17409
2018_02_supporting_data.xlsx	xlsx	90282

Report Last Saved By

CALDWELL, CITY OF

User: kchattin@cityofcaldwell.org
 Name: Kaitlin Chattin
 E-Mail: kchattin@cityofcaldwell.org
 Date/Time: 2018-03-20 12:37 (Time Zone: -07:00)

Report Last Signed By

User: sarreola@cityofcaldwell.org
 Name: Salvador Arreola
 E-Mail: sarreola@cityofcaldwell.org
 Date/Time: 2018-03-20 12:37 (Time Zone: -07:00)