



45613	Floating solids, waste or visible foam-visual	Q - See Comments	0	--	Sample	=	0	9P - N=0;Y=1									01/30 - Monthly	VI - VISUAL
					Permit Req.	<=	0 MO MAX	9P - N=0;Y=1									01/30 - Monthly	VI - VISUAL
					Value NODI													
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	6.013	03 - MGD									99/99 - Continuous	RC - Recorder (auto)
					Permit Req.		Req Mon MO AVG	Req Mon DAILY MX	03 - MGD								99/99 - Continuous	RC - Recorder (auto)
					Value NODI													
81010	BOD, 5-day, percent removal	K - Percent Removal	0	--	Sample	=		98.4									01/30 - Monthly	CA - CALCTD
					Permit Req.	>=		85 MO AV MN									01/30 - Monthly	CA - CALCTD
					Value NODI													
81011	Solids, suspended percent removal	K - Percent Removal	0	--	Sample	=		98.2									01/30 - Monthly	CA - CALCTD
					Permit Req.	>=		85 MO AV MN									01/30 - Monthly	CA - CALCTD
					Value NODI													

**Submission Note**

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**

No errors.

**Comments**

**Attachments**

Name	Type	Size
2018_04_ALL_Lab_Statement.pdf	pdf	17595
2018_04_WWTP_Lab_Statement.pdf	pdf	49341
2018_04_supporting_data.xlsx	xlsx	93893

**Report Last Saved By**

CALDWELL, CITY OF

User: rhawker@cityofcaldwell.org  
 Name: Rodger Hawker  
 E-Mail: rhawker@cityofcaldwell.org  
 Date/Time: 2018-05-21 13:48 (Time Zone: -07:00)

**Report Last Signed By**

User: sarreola@cityofcaldwell.org  
 Name: Salvador Arreola  
 E-Mail: sarreola@cityofcaldwell.org  
 Date/Time: 2018-05-21 13:48 (Time Zone: -07:00)